



Shasta County

DEPARTMENT OF RESOURCE MANAGEMENT
1855 Placer Street, Redding, CA 96001

Richard W. Simon, AICP
Director

Dale J. Fletcher, CBO
Assistant Director

July 23, 2018

Max Snyder
Igo Inn
6372 Hemlock Street
Redding, CA 96001

CITATION NO. 01_75_18C_021_45000312_23 FOR IGO INN WATER SYSTEM# 4500312 SECOND QUARTER 2018, FAILURE TO MONITOR FOR BACTERIOLOGICAL WATER QUALITY

The Igo Inn Water System is classified as a transient/non-community public water system which is required to collect one routine sample per quarter for coliform bacteria as prescribed under Sections 64423 and 64424 of Title 22, California Code of Regulations (Title 22). During the second quarter of 2018, Maw Snyder did not submit a copy of a laboratory analysis to this office for review by July 10, 2018, or did not collect its routine bacteriological water sample from the distribution system. Therefore, this Citation is being issued to the Igo Inn Water System for violating the bacteriological monitoring and reporting requirements for the second quarter of 2018.

The Igo Inn Water System owner is hereby directed to take the following actions:

1. As required under Section 64463.7 of Title 22, provide public notification to customers within one year of this notice of violation. Enclosure 'A' is a format you may use to fulfill the above public notification requirements. If you wish to propose any change to this notification, please contact our office.
2. Provide two types of public notification: 1) Posting in conspicuous locations throughout the area served by the water system; and 2) mail or hand deliver copies to each water user.
3. Complete and return Enclosure 'B' "Certification of Completion of Public Notification" form within 10 days of giving public notice.
4. The Igo Inn Water System representatives shall comply with Section 64423, Title 22, CCR, in all future monitoring periods.

Failure to comply with the directives of this citation may result in further enforcement action with the possibility of administrative penalties.

Suite 101

IR QUALITY MANAGEMENT DISTRICT
(4) 225-5674

(x) 530 225-5237

☐ Suite 102

BUILDING DIVISION
530 225-5761

Fax 530 245-6468

☐ Suite 103

PLANNING DIVISION
530 225-5532

Fax 530 245-6468

☒ Suite 201

ENVIRONMENTAL HEALTH DIVISION
530 225-5787

Fax 530 225-5413

☐ Suite 200

ADMINISTRATION & COMMUNITY EDUCATION

530 225-5789


Fax 530 225-5807

Max Snyder
Page 2
July 23, 2018

Note that Section 116577 of the California Safe Drinking Water Act provides for the Shasta County Environmental Health Division to be reimbursed by the public water system for costs incurred for preparing and issuing a citation to that system. In accordance with Section 116577, Max Snyder is hereby charged for the preparation and issuance of this letter. Our current costs are \$129.83 per hour. The estimated time to prepare this citation is one hour (\$129.83). Please submit your payment with the certification form requested in item three (3) above.

Please contact me at 530/225-5787, Monday through Friday, between 8:00 and 8:30 a.m. should you have any questions or concerns.

Sincerely,

A handwritten signature in cursive script, appearing to read "Christy Gilbreath".

Christy Gilbreath, REHS
Registered Environmental Health Specialist

CG/pw

Enclosures